

WARNING

DO YOU KNOW?

There are **some parts that have an expiry date** on the automatic fire suppression system "CABINEX".

5
years

replace within 5 years
after installation



Start up unit
GHK-10WT

5
years

replace within 5 years
after installation



Heat detector
THIS-10



Flame detector
SX-7000

5
years

replace within 5 years
after installation



Batteries
12Vx2




CABINEX-EWT



EN2

EWT

Example of installation



HERE

Maintenance should be carried out every 6 months by qualified and trained personnels.
See the other side for details.



MAINTENANCE NEEDED

WARNING

To make sure the automatic fire suppression system “CABINEX” functions reliably when fire occurs.



CABINEX-EN2

SERIOUS ACCIDENTS!

should be occurred

Start up unit is locked!

Remain powered off!

Replacement parts (see the other side) are not be replaced!

Fire detectors are damaged and corrosion!

Extinguishing agent is empty!

For production lines, it is necessary to extinguish the fire reliably in the event of a fire emergency. By doing the maintenance, you can discover the defect in advance and keep the flawless fire safety measures. Though there is no legal obligation, maintenance should be carried out every 6 months. CABINEX has “replacement parts” (see the other side) that should be replaced regularly.

Recommendation of Maintenance Contract

- ★ There is a possibility that CABINEX will not activate in spite of spending a lot for the installation.
 - ★ If you wait until after a fire, the cost and time for recovery will hugely increase.
- By doing the maintenance of CABINEX, you can reduce the cost, achieve safety and feel at ease.
- ★ By doing the maintenance of CABINEX, you can keep valuable production lines and equipment running, and protect your employees from fire.

Contact

Manufacture



HATSUTA SEISAKUSHO CO., LTD
3-5 SHODAI-TAJIKA, HIRAKATA,
OSAKA 573-1132, JAPAN
PHONE : +81-72-856-1292
URL : www.hatsuta.co.jp

WARNING